

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106 1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client : Basford Bra 16 - 20 App	ands Pty Ltd	Test Number Issue Date	: 18-00400 : 24/07/20	
Breakwater		Print Date	: 24/07/201	
Sample Description	Clients Ref : "Tasman - Translucent"			
	Polyester translucent blind fabric			
	Colour : Grey			
	End Use : Blinds Nominal Composition : 100% Polyester			
	•	g/m2		
	Nominal Thickness : Approx: 0.36mm	5		
/NZS 1530.3-1999	Methods for Fire Tests on Building Materials, C	-	res	
	Part 3: Simultaneous Determination of Ignitabi Flame Propagation, Heat Release and Smoke F	•		
	Face tested:	Face		
	Date tested:	24/07/2018		
		Standard Error	Mean	
	Ignition time	1.47	9.39	min
	Flame propagation time	4.4	20.7	sec
	Heat release integral	5.2	60.7	kJ/m²
	Smoke release, log d	0.0693	-0.4935	
	Optical density, d		0.3288	/ metre
	No of samples which ignited		3	
	For Samples which ignited			
	Smoke Release (Log D) - Mean		-0.4935	
	Smoke Release (Log D) - Standard Error		0.0693	
	No of samples which did not ignite		6	
	For Samples which did not ignite			
	Smoke Release (Log D) - Mean		-0.9302	
	Smoke Release (Log D) - Standard Error		0.0755	
136868 29	241		Page 1	- 6 0

© Australian Wool testing Authority Ltd Copyright - All Rights Reserved

NATA	Accredited for compliance with ISO/IEC 17025 - Testing - Chemical Testing - Mechanical Testing
\checkmark	- Performance & Approvals Testing

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

HAFL A. JACKSON B.Sc.(Hons)

SADM

APPROVED SIGNATORY

: Accreditation No.

: Accreditation No.

: Accreditation No.

983

985

1356



Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106 1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client :	Basford Brands Pty Ltd 16 - 20 Apparel Close Breakwater VIC 3219	Test Number Issue Date Print Date	: : :	18-004002 24/07/2018 24/07/2018	
	Number of specimens tested:			9	

Number of specimens tested:

Regulatory Indices:		
Ignitability Index	11	Range 0-20
Spread of Flame Index	9	Range 0-10
Heat Evolved Index	2	Range 0-10
Smoke Developed Index	6	Range 0-10

The reaction of thin unsupported flexible materials to flame impingement can be assessed in accordance with AS 1530.2. Where materials of thickness less than 2mm that are sufficiently flexible to be bent by hand around a mandrel of 2mm diameter or less are subjected to the test described herein, they should also be subjected to the test in AS 1530.2.

Ignition is initiated by a pilot flame that is held near, but does not touch the specimen . A material that does not ignite during the standard test may ignite if contacted with a pilot flame during the test

Inconsistent flame spread behaviour was observed. Only <#No of specimens spread#> of the 9 specimens registered flame spread. The Spread of Flame Index guoted above is based on these <#No of specimens spread#> specimens.

The specimens were mounted to simulate use in an unsupported or free hanging mode. The results may be significantly different when mounted to simulate a wall cladding or upholstery application .

To allow free movement of sample during testing all corners were folded away from the clamps.

Each test specimen was sandwiched between two layers of galvanised welded square mesh made from wire of nominal diameter 0.8mm and nominal spacing 12mm in both directions, stapled through at four points, each 100mm from the centre of the sample and the assembly clamped in four places.

These results only apply to the specimen mounted, as described in this report. The result of this fire test may be used to directly assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all fire conditions.

